



**Town of Scituate, MA**  
**MS4 General Permit Year 4**  
**Dry Weather Outfall Screening Results**

Outfall ID	Inspection Date	Sampling Location	Upstream Sample Location <sup>1,2</sup>	Weather	Ambient Temperature (°F)	Precipitation within 24 Hours	Flow Present	Ammonia (ppm)	Surfactants (ppm)	Chlorine (ppm)	pH	Sample Temperature (°C)	Specific Conductivity (µS)	Salinity (ppt)	E. Coli (MPN/100mL)	Enterococcus	Total Phosphorus (mg/L)
13-000-002	4/5/2022	Outfall	--	Sunny	52	<0.1	Yes	2	0.25	0.01	6.44	15	214	0.1	<10	--	--
36-000-002	1/24/2022	Outfall	--	Sunny	28	<0.1	Yes	0.6	2	0.46	7.45	5.8	363	0.2	<10	--	--
SDE-OF2	1/19/2022	Outfall	--	Cloudy	43	<0.1	Yes	2	0.25	0.2	6.14	5.8	311	0.3	<10	--	--
35-000-002	4/21/2022	Outfall	--	Sunny	54	<0.1	Yes	0.1	0.25	<0.02	6.83	63.9	6285	0.3	1,081	--	--
37-000-001	4/29/2022	Upstream Structure	1470	Sunny	49	<0.1	Yes	5	<0.125	<0.02	7.47	12.9	568	0.3	6,131	--	--
46-000-001	5/20/2022	Outfall	--	Sunny	59	<0.1	Yes	<0.02	<0.125	<0.02	8.01	18.4	409	0.2	2,987	--	--
32-000-004	3/23/2022	Upstream Structure	770	Sunny	39	<0.1	Yes	<0.02	0.25	<0.02	7.36	8.7	1392	0.7	10	--	--
01-000-001	4/29/2022	Outfall	--	Sunny	44	<0.1	Yes	<0.02	0.25	<0.02	7.15	12.4	388	0.2	10	--	--
03-000-001	4/29/2022	Outfall	--	Sunny	45	<0.1	Yes	<0.02	<0.125	<0.02	6.64	14.3	969	0.5	10	--	--
06-000-003	4/4/2022	Outfall	--	Sunny	46	<0.1	Yes	<0.02	0.25	0.67	7.37	12.7	431	0.2	10	--	--
07-000-001	3/17/2022	Upstream Structure	286	Cloudy	46	<0.1	Yes	0.1	0.75	0.02	5.86	9.7	422	0.2	<10	--	--
10-000-007	3/9/2022	Outfall	--	Cloudy	34	<0.1	Yes	<0.02	0.25	<0.02	6.43	7.2	6.5	0	<10	--	--
13-000-001	4/5/2022	Outfall	--	Sunny	54	<0.1	Yes	0.4	0.5	<0.02	6.66	11.2	605	0.3	<10	--	--
13-000-003	4/5/2022	Outfall	--	Sunny	52	<0.1	Yes	<0.02	0.25	0.07	6.75	12	379	0.2	<10	--	--
14-000-002	4/5/2022	Upstream Structure	1712	Sunny	55	<0.1	Yes	0.1	0.25	0.11	6.31	16.2	541	0.3	<10	--	--
14-000-003	4/22/2022	Outfall	--	Sunny	65	<0.1	Yes	0.3	0.25	<0.02	6.31	61.9	278	0.1	<10	--	--
14-000-004	4/22/2022	Upstream Structure	1709	Sunny	64	<0.1	Yes	0.3	0.25	0.19	6.11	63.6	363	0.2	<10	--	--
20-000-005	3/31/2022	Upstream Structure	451	Cloudy	48	<0.1	Yes	<0.02	0.5	<0.02	6.23	11.9	831	0.4	<10	--	--
21-000-004	3/9/2022	Upstream Structure	707	Cloudy	40	<0.1	Yes	<0.02	0.5	0.14	6.47	5.4	1045	0.5	--	7.2	--
22-000-003	4/13/2022	Outfall	--	Sunny	63	<0.1	Yes	<0.02	0.75	<0.02	6.95	14.1	553	0.3	20	--	--
22-000-004	3/23/2022	Outfall	--	Sunny	40	<0.1	Yes	<0.02	0.25	<0.02	6.84	8.7	600	0.3	20	--	--
22-000-008	3/23/2022	Outfall	--	Sunny	48	<0.1	Yes	<0.02	0.25	<0.02	6.43	9.5	276	0.1	<10	--	--
22-000-009	3/23/2022	Outfall	--	Sunny	40	<0.1	Yes	<0.02	0.25	<0.02	6.72	11.4	282	0.1	<10	--	--
23-000-001	4/13/2022	Outfall	--	Sunny	64	<0.1	Yes	0.1	0.5	<0.02	6.45	13.7	488	0.2	10	--	--
23-000-003	4/13/2022	Upstream Structure	1533	Sunny	60	<0.1	Yes	<0.02	<0.125	0.09	6.12	15.1	341	0.1	<10	--	--
23-000-007	4/5/2022	Upstream Structure	1615	Sunny	55	<0.1	Yes	<0.02	0.25	<0.02	7.31	14.9	647	0.3	<10	--	--



**Town of Scituate, MA**  
**MS4 General Permit Year 4**  
**Dry Weather Outfall Screening Results**

24-000-001	4/29/2022	Upstream Structure	Unmapped catch basin (SW inlet) stream is flowing into	Sunny	48	<0.1	Yes	0.25	0.25	<0.02	6.85	15.1	194.1	0.1	<10	--	--
24-000-007	4/13/2022	Outfall	--	Sunny	60	<0.1	Yes	<0.02	<0.125	<0.02	6.9	14.2	4070	0.2	10	--	--
29-000-001	3/31/2022	Upstream Structure	388	Cloudy	48	<0.1	Yes	0.1	0.25	0.15	6.16	11.6	625	0.3	<10	--	--
29-000-002	3/31/2022	Outfall	--	Cloudy	48	<0.1	Yes	<0.02	0.25	0.03	6.45	11.5	481	0.2	<10	--	--
32-000-006	1/19/2022	Outfall	--	Cloudy	34	<0.1	Yes	<0.02	0.25	<0.02	7.12	3.2	374	0.2	<10	--	--
32-000-007	1/19/2022	Outfall	--	Cloudy	34	<0.1	Yes	<0.02	0.25	<0.02	6.64	6	420	0.2	10	--	--
34-000-002	4/13/2022	Upstream Structure	1121	Sunny	69	<0.1	Yes	<0.02	0.25	0.19	6.34	18	695	0.3	<10	--	--
35-000-001	2/21/2022	Outfall	--	Sunny	48	<0.1	Yes	<0.02	0.25	<0.02	6.64	8.7	405	0.2	<10	--	--
35-000-006	3/23/2022	Outfall	--	Sunny	42	<0.1	Yes	<0.02	0.5	<0.02	6.52	10.1	306	0.1	<10	--	--
35-000-012	4/21/2022	Upstream Structure	Unmapped manhole directly upstream of outfall	Sunny	55	<0.1	Yes	<0.02	0.25	<0.02	7.5	55.8	8380	0.4	10	--	--
37-000-002	4/29/2022	Upstream Structure	1300	Sunny	50	<0.1	Yes	<0.02	<0.125	<0.02	7.46	13.9	339	0.2	<10	--	--
38-000-001	2/16/2022	Outfall	--	Sunny	41	<0.1	Yes	0.3	0.5	<0.02	7.49	7.2	394	0.2	<10	--	--
43-000-002	4/22/2022	Upstream Structure	428	Cloudy	54	<0.1	Yes	<0.02	0.25	0.12	6.02	52.1	897	0.4	<10	--	--
46-000-003	3/23/2022	Outfall	--	Sunny	48	<0.1	Yes	<0.02	<0.125	<0.02	6.38	10.7	307	0.1	10	--	--
46-000-007	2/16/2022	Outfall	--	Sunny	36	<0.1	Yes	<0.02	0.25	0.06	7.61	5.6	637	0.3	<10	--	--
47-000-003	4/4/2022	Outfall	--	Sunny	51	<0.1	Yes	<0.02	0.25	<0.02	6.57	15	451	0.2	<10	--	--
48-000-009	2/21/2022	Outfall	--	Sunny	38	<0.1	Yes	0.1	1	<0.02	7.51	6.3	466	0.2	20	--	--
51-000-002	2/16/2022	Upstream Structure	1325	Sunny	19	<0.1	Yes	<0.02	0.25	0.04	7.77	5.7	606	0.3	10	--	--
52-000-004	1/26/2022	Outfall	--	Sunny	27	<0.1	Yes	0.2	0.25	0.31	6.49	2	349	0.1	<10	--	--
52-000-007	1/26/2022	Outfall	--	Sunny	25	<0.1	Yes	<0.02	<0.125	0.19	7.14	3.9	334	0.1	<10	--	--
52-000-009	2/16/2022	Outfall	--	Sunny	32	<0.1	Yes	<0.02	0.75	0.02	7.91	5.8	805	0.4	<10	--	--
53-000-005	2/16/2022	Outfall	--	Sunny	23	<0.1	Yes	<0.02	<0.125	<0.02	7.66	4.2	606	0.3	98	--	--
53-000-014	5/20/2022	Upstream Structure	2566	Cloudy	55	<0.1	Yes	0.2	<0.125	0.18	8.6	16.9	254	0.1	41	--	--
54-000-005	4/21/2022	Outfall	--	Sunny	51	<0.1	Yes	<0.02	0.75	0.13	6.48	54.5	9790	5.4	--	41	--
55-000-008	4/4/2022	Outfall	--	Sunny	41	<0.1	Yes	<0.02	<0.125	0.03	9.43	11.3	443	0.2	--	<10	--
57-000-002	4/22/2022	Upstream Structure	853	Sunny	63	<0.1	Yes	0.1	<0.125	0.55	6.47	16.8	501	0.3	<10	--	--
59-000-001	4/22/2022	Outfall	--	Sunny	63	<0.1	Yes	<0.02	<0.125	0.14	6.27	17.7	496	0.2	<10	--	--



**Town of Scituate, MA**  
**MS4 General Permit Year 4**  
**Dry Weather Outfall Screening Results**

61-000-002	4/22/2022	Outfall	--	Sunny	55	<0.1	Yes	<0.02	0.25	<0.02	6.31	55.9	713	0.3	96	--	--
62-000-004	2/16/2022	Outfall	--	Sunny	32	<0.1	Yes	0.2	0.25	<0.02	7.72	5.1	316	0.1	<10	--	--
62-000-005	4/22/2022	Outfall	--	Sunny	63	<0.1	Yes	0.1	<0.125	<0.02	6.95	19	331	0.2	--	<10	--
62-000-007	4/29/2022	Outfall	--	Sunny	51	<0.1	Yes	<0.02	0.25	<0.02	6.84	15.3	373	0.2	20	--	--
62-000-009	2/16/2022	Outfall	--	Sunny	32	<0.1	Yes	<0.02	0.25	0.14	8.17	6.1	1151	0.6	<10	--	--
62-000-010	2/16/2022	Outfall	--	Sunny	19	<0.1	Yes	<0.02	0.75	<0.02	7.86	4.8	570	0.3	<10	--	--
70-000-001	1/26/2022	Outfall	--	Sunny	26	<0.1	Yes	0.3	<0.125	0.06	7.01	5.9	442	0.2	<10	--	--
70-000-006	1/24/2022	Outfall	--	Sunny	27	<0.1	Yes	<0.02	<0.125	0.11	7.63	1.1	622	0.3	--	<10	0.02
70-000-007	1/24/2022	Outfall	--	Sunny	27	<0.1	Yes	0.3	<0.125	<0.02	7.79	1	269	0.1	--	<10	0.021
81-000-001	4/22/2022	Outfall	--	Sunny	59	<0.1	Yes	<0.02	0.25	<0.02	7.03	58.8	347	0.2	2	--	--
SDE-OF1	1/19/2022	Outfall	--	Cloudy	43	<0.1	Yes	<0.02	0.25	0.12	6.64	7.2	405	0.2	<10	--	--
WC-001	1/26/2022	Outfall	--	Sunny	26	<0.1	Yes	<0.02	<0.125	0.22	7.29	1.8	318	0.1	2	--	--
WC-016	4/22/2022	Outfall	--	Sunny	60	<0.1	Yes	0.1	0.5	<0.02	6.59	63.1	864	0.4	--	<10	--
WC-024	3/31/2022	Outfall	--	Cloudy	48	<0.1	Yes	<0.02	0.25	<0.02	6.53	12.8	176.2	0	<10	--	--
WC-030	4/13/2022	Outfall	--	Sunny	69	<0.1	Yes	0.2	0.25	<0.02	6.33	13.6	364	0.2	146	--	--
WC-033	4/29/2022	Outfall	--	Sunny	47	<0.1	Yes	<0.02	0.5	0.14	7.32	10.7	1145	0.6	<10	--	--
WC-034	3/9/2022	Outfall	--	Cloudy	40	<0.1	Yes	<0.02	0.5	0.04	7.05	6.1	1457	0.7		<1	--
WC-043	3/17/2022	Outfall	--	Cloudy	50	<0.1	Yes	<0.02	0.25	<0.02	6.93	12.5	784	0.4	<10	--	--
20-000-001	4/13/2022	Upstream Structure	123	Sunny	58	<0.1	Yes	<0.02	<0.125	<0.02	6.82	14.3	166	0	<10	--	--
36-000-006	1/24/2022	Outfall	--	Sunny	28	<0.1	Yes	<0.02	<0.125	<0.02	7.51	5.7	297	0.1	<10	--	--
49-000-001	1/26/2022	Outfall	--	Sunny	24	<0.1	Yes	<0.02	<0.125	<0.02	7.58	0.25	243	0.1	<10	--	--
52-000-006	1/26/2022	Outfall	--	Sunny	25	<0.1	Yes	<0.02	<0.125	<0.02	7.38	1.9	508	0.2	<10	--	--
52-000-008	2/16/2022	Upstream Structure	1394	Sunny	41	<0.1	Yes	<0.02	<0.125	<0.02	7.74	6.3	617	0.3	<10	--	--
53-000-008	2/16/2022	Upstream Structure	2633	Sunny	23	<0.1	Yes	<0.02	<0.125	<0.02	7.65	5.1	937	0.4	<10	--	--
53-000-011	2/16/2022	Outfall	--	Sunny	25	<0.1	Yes	<0.02	<0.125	<0.02	7.65	6	625	0.3	<10	--	--
68-000-010	1/24/2022	Outfall	--	Sunny	27	<0.1	Yes	<0.02	<0.125	<0.02	8.02	6.8	272	0.1	<10	--	--
WC-042	1/24/2022	Outfall	--	Sunny	27	<0.1	Yes	<0.02	<0.125	<0.02	7.63	3.6	314	0.1	<10	--	--
07-000-007	4/5/2022	--	--	Sunny	52	<0.1	No	--	--	--	--	--	--	--	--	--	--
11-000-002	3/9/2022	Upstream Structure	195	Cloudy	36	<0.1	No	--	--	--	--	--	--	--	--	--	--
21-000-002	3/9/2022	Upstream Structure	703	Cloudy	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
21-000-003	3/9/2022	Upstream Structure	700	Cloudy	39	<0.1	No	--	--	--	--	--	--	--	--	--	--
32-000-002	3/31/2022	Outfall	--	Cloudy	48	<0.1	No	--	--	--	--	--	--	--	--	--	--
32-000-005	3/31/2022	Outfall	--	Cloudy	48	<0.1	No	--	--	--	--	--	--	--	--	--	--
34-000-003	4/14/2022	Upstream Structure	1151	Cloudy	46	<0.1	No	--	--	--	--	--	--	--	--	--	--



**Town of Scituate, MA**  
**MS4 General Permit Year 4**  
**Dry Weather Outfall Screening Results**

34-000-006	4/14/2022	Upstream Structure	739	Cloudy	46	<0.1	No	--	--	--	--	--	--	--	--	--	--
35-000-005	4/22/2022	Upstream Structure	1120	Sunny	60	<0.1	No	--	--	--	--	--	--	--	--	--	--
35-000-010	4/22/2022	Outfall	--	Sunny	63	<0.1	No	--	--	--	--	--	--	--	--	--	--
36-000-004	1/24/2022	Outfall	--	Sunny	30	<0.1	No	--	--	--	--	--	--	--	--	--	--
36-000-005	1/24/2022	Outfall	--	Sunny	28	<0.1	No	--	--	--	--	--	--	--	--	--	--
37-000-003	1/25/2022	Upstream Structure	1289	Cloudy	37	<0.1	No	--	--	--	--	--	--	--	--	--	--
37-000-004	1/25/2022	--	--	Cloudy	35	<0.1	No	--	--	--	--	--	--	--	--	--	--
37-000-005	1/25/2022	Upstream Structure	1282	Cloudy	37	<0.1	No	--	--	--	--	--	--	--	--	--	--
38-000-002	1/25/2022	--	--	Cloudy	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
38-000-004	2/16/2022	Outfall	--	Sunny	41	<0.1	No	--	--	--	--	--	--	--	--	--	--
38-000-007	4/14/2022	Upstream Structure	1439	Cloudy	46	<0.1	No	--	--	--	--	--	--	--	--	--	--
42-000-003	1/12/2022	Outfall	--	Sunny	37	<0.1	No	--	--	--	--	--	--	--	--	--	--
42-000-004	1/12/2022	--	--	Sunny	30	<0.1	No	--	--	--	--	--	--	--	--	--	--
48-000-002	2/21/2022	Outfall	--	Sunny	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
50-000-002	2/21/2022	Upstream Structure	1056	Sunny	48	<0.1	No	--	--	--	--	--	--	--	--	--	--
50-000-003	1/25/2022	Upstream Structure	1365	Cloudy	36	<0.1	No	--	--	--	--	--	--	--	--	--	--
52-000-005	1/25/2022	--	--	Cloudy	34	<0.1	No	--	--	--	--	--	--	--	--	--	--
53-000-002	1/25/2022	Outfall	--	Cloudy	39	<0.1	No	--	--	--	--	--	--	--	--	--	--
53-000-009	1/25/2022	Upstream Structure	2628	Cloudy	39	<0.1	No	--	--	--	--	--	--	--	--	--	--
53-000-012	2/16/2022	Upstream Structure	2828	Sunny	25	<0.1	No	--	--	--	--	--	--	--	--	--	--
53-000-013	1/25/2022	Outfall	--	Cloudy	39	<0.1	No	--	--	--	--	--	--	--	--	--	--
55-000-003	5/20/2022	Upstream Structure	549	Cloudy	55	<0.1	No	--	--	--	--	--	--	--	--	--	--
56-000-001	1/12/2022	Outfall	--	Sunny	39	<0.1	No	--	--	--	--	--	--	--	--	--	--
56-000-002	1/12/2022	Outfall	--	Sunny	37	<0.1	No	--	--	--	--	--	--	--	--	--	--
56-000-003	1/12/2022	Outfall	--	Sunny	30	<0.1	No	--	--	--	--	--	--	--	--	--	--
58-000-005	5/20/2022	Upstream Structure	817	Sunny	56	<0.1	No	--	--	--	--	--	--	--	--	--	--
64-000-001	3/17/2022	Outfall	--	Cloudy	42	<0.1	No	--	--	--	--	--	--	--	--	--	--
65-000-003	1/25/2022	--	--	Sunny	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
65-000-005	1/25/2022	Outfall	--	Sunny	40	<0.1	No	--	--	--	--	--	--	--	--	--	--
65-000-006	1/25/2022	--	--	Sunny	38	<0.1	No	--	--	--	--	--	--	--	--	--	--



**Town of Scituate, MA**  
**MS4 General Permit Year 4**  
**Dry Weather Outfall Screening Results**

65-000-007	1/25/2022	Outfall	--	Sunny	40	<0.1	No	--	--	--	--	--	--	--	--	--	--
68-000-003	4/22/2022	Outfall	--	Sunny	64	<0.1	No	--	--	--	--	--	--	--	--	--	--
70-000-002	1/26/2022	Outfall	--	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
70-000-010	4/12/2022	Upstream Structure	67	Cloudy	54	<0.1	No	--	--	--	--	--	--	--	--	--	--
70-000-011	1/24/2022	Upstream Structure	2151	Sunny	28	<0.1	No	--	--	--	--	--	--	--	--	--	--
70-000-015	1/24/2022	Upstream Structure	2152	Sunny	25	<0.1	No	--	--	--	--	--	--	--	--	--	--
71-000-001	1/26/2022	Upstream Structure	2472	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
73-000-001	5/20/2022	Upstream Structure	Unmapped upstream catch basin	Cloudy	55	<0.1	No	--	--	--	--	--	--	--	--	--	--
73-000-003	1/26/2022	Upstream Structure	2908	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
73-000-007	12/26/2021	Outfall	--	Sunny	35	<0.1	No	--	--	--	--	--	--	--	--	--	--
76-000-001	1/26/2022	Outfall	--	Sunny	23	<0.1	No	--	--	--	--	--	--	--	--	--	--
76-000-004	1/26/2022	Outfall	--	Sunny	23	<0.1	No	--	--	--	--	--	--	--	--	--	--
78-000-002	1/26/2022	Outfall	--	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
78-000-003	4/22/2022	--	2405	Sunny	59	<0.1	No	--	--	--	--	--	--	--	--	--	--
83-000-001	4/21/2022	Upstream Structure	2848	Sunny	46	<0.1	No	--	--	--	--	--	--	--	--	--	--
83-000-004	4/12/2022	Upstream Structure	2850	Cloudy	55	<0.1	No	--	--	--	--	--	--	--	--	--	--
SDE-OF3	1/19/2022	Outfall	--	Cloudy	43	<0.1	No	--	--	--	--	--	--	--	--	--	--
WC-002	1/26/2022	Upstream Structure	Unmapped manhole	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
WC-032	3/9/2022	Outfall	--	Cloudy	40	<0.1	No	--	--	--	--	--	--	--	--	--	--
WC-039	2/21/2022	Outfall	--	Sunny	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
35-000-011	4/22/2022	Upstream Structure	1069	Sunny	63	<0.1	No	--	--	--	--	--	--	--	--	--	--
47-000-001	4/4/2022	Upstream Structure	793	Sunny	51	<0.1	No	--	--	--	--	--	--	--	--	--	--
49-000-006	2/21/2022	Upstream Structure	1005	Sunny	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
54-000-016	4/21/2022	--	2749	Sunny	52	<0.1	No	--	--	--	--	--	--	--	--	--	--



**Town of Scituate, MA**  
**MS4 General Permit Year 4**  
**Dry Weather Outfall Screening Results**

58-000-004	5/20/2022	Upstream Structure	819	Sunny	57	<0.1	No	--	--	--	--	--	--	--	--	--	--
70-000-004	3/17/2022	Upstream Structure	2441	Cloudy	42	<0.1	No	--	--	--	--	--	--	--	--	--	--
06-000-004	4/5/2022	Upstream Structure	266	Sunny	52	<0.1	No	--	--	--	--	--	--	--	--	--	--
11-000-003	3/9/2022	Upstream Structure	204	Cloudy	36	<0.1	No	--	--	--	--	--	--	--	--	--	--
14-000-001	4/22/2022	Upstream Structure	1725	Sunny	64	<0.1	No	--	--	--	--	--	--	--	--	--	--
22-000-005	3/23/2022	Outfall	--	Sunny	45	<0.1	No	--	--	--	--	--	--	--	--	--	--
23-000-005	1/24/2022	Upstream Structure	1177	Sunny	32	<0.1	No	--	--	--	--	--	--	--	--	--	--
34-000-005	4/14/2022	Upstream Structure	741	Cloudy	46	<0.1	No	--	--	--	--	--	--	--	--	--	--
35-000-004	3/9/2022	Upstream Structure	1071	Cloudy	39	<0.1	No	--	--	--	--	--	--	--	--	--	--
36-000-003	1/24/2022	Upstream Structure	1178	Sunny	30	<0.1	No	--	--	--	--	--	--	--	--	--	--
46-000-006	2/16/2022	Upstream Structure	820	Sunny	36	<0.1	No	--	--	--	--	--	--	--	--	--	--
56-000-004	1/12/2022	Upstream Structure	858	Sunny	37	<0.1	No	--	--	--	--	--	--	--	--	--	--
64-000-002	3/17/2022	Upstream Structure	2642	Cloudy	42	<0.1	No	--	--	--	--	--	--	--	--	--	--
70-000-016	3/17/2022	Upstream Structure	2150	Cloudy	45	<0.1	No	--	--	--	--	--	--	--	--	--	--
47-000-005	4/4/2022	Upstream Structure	787	Sunny	51	<0.1	No	--	--	--	--	--	--	--	--	--	--
48-000-003	2/21/2022		915	Sunny	48	<0.1	No	--	--	--	--	--	--	--	--	--	--
48-000-010	2/21/2022	Upstream Structure	1007	Sunny	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
65-000-008	4/21/2022	--	2513	Sunny	52	<0.1	No	--	--	--	--	--	--	--	--	--	--
82-000-001	4/22/2022	Upstream Structure	2411	Sunny	60	<0.1	No	--	--	--	--	--	--	--	--	--	--
WC-003	1/26/2022	Outfall	--	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--





**Town of Scituate, MA**  
**MS4 General Permit Year 4**  
**Dry Weather Outfall Screening Results**

WC-004	1/26/2022	Outfall	--	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
WC-005	1/26/2022	Outfall	--	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
WC-029	3/31/2022	Outfall	--	Cloudy	48	<0.1	No	--	--	--	--	--	--	--	--	--	--
52-000-001	1/25/2022	Outfall	--	Cloudy	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
38-000-003	1/25/2022	--	--	Cloudy	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
23-000-002	4/5/2022	Upstream Structure	1528	Sunny	55	<0.1	No	--	--	--	--	--	--	--	--	--	--
29-000-005	1/12/2022	--	--	Sunny	37	<0.1	Yes	--	--	--	--	--	--	--	--	--	--
38-000-008	4/14/2022	Upstream Structure	1435	Cloudy	46	<0.1	Yes	--	--	--	--	--	--	--	--	--	--
46-000-008	2/16/2022	Outfall	--	Sunny	36	<0.1	Yes	--	--	--	--	--	--	--	--	--	--
47-000-004	4/4/2022	--	--	Sunny	51	<0.1	No	--	--	--	--	--	--	--	--	--	--
48-000-001	2/21/2022	Outfall	--	Sunny	38	<0.1	Yes	--	--	--	--	--	--	--	--	--	--
52-000-002	1/25/2022	Outfall	--	Cloudy	38	<0.1	Yes	--	--	--	--	--	--	--	--	--	--
75-000-003	3/17/2022	Outfall	--	Cloudy	45	<0.1	No	--	--	--	--	--	--	--	--	--	--
WC-044	3/17/2022	Outfall	--	Cloudy	50	<0.1	No	--	--	--	--	--	--	--	--	--	--
06-000-002	4/29/2022	--	--	Sunny	45	<0.1	No	--	--	--	--	--	--	--	--	--	--
10-000-006	3/9/2022	Outfall	--	Cloudy	34	<0.1	No	--	--	--	--	--	--	--	--	--	--
19-000-005	3/31/2022	--	--	Cloudy	48	<0.1	No	--	--	--	--	--	--	--	--	--	--
19-000-006	1/19/2022	--	--	Sunny	34	<0.1	No	--	--	--	--	--	--	--	--	--	--
20-000-006	3/31/2022	--	--	Cloudy	48	<0.1	No	--	--	--	--	--	--	--	--	--	--
20-000-007	3/31/2022	--	--	Cloudy	48	<0.1	No	--	--	--	--	--	--	--	--	--	--
25-000-002	4/4/2022	Outfall	--	Sunny	41	<0.1	No	--	--	--	--	--	--	--	--	--	--
26-000-003	4/4/2022	Outfall	--	Sunny	41	<0.1	No	--	--	--	--	--	--	--	--	--	--
29-000-003	1/12/2022	--	--	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
29-000-004	1/12/2022	Outfall	--	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
32-000-001	1/19/2022	--	--	Cloudy	39	<0.1	No	--	--	--	--	--	--	--	--	--	--
33-000-001	1/19/2022	--	--	Cloudy	43	<0.1	No	--	--	--	--	--	--	--	--	--	--
33-000-002	1/19/2022	--	--	Cloudy	43	<0.1	No	--	--	--	--	--	--	--	--	--	--



**Town of Scituate, MA**  
**MS4 General Permit Year 4**  
**Dry Weather Outfall Screening Results**

34-000-004	4/14/2022	Outfall	--	Cloudy	46	<0.1	No	--	--	--	--	--	--	--	--	--	--
35-000-009	4/22/2022	--	--	Sunny	60	<0.1	No	--	--	--	--	--	--	--	--	--	--
46-000-004	5/20/2022	--	--	Sunny	61	<0.1	No	--	--	--	--	--	--	--	--	--	--
48-000-006	2/21/2022	Outfall	--	Sunny	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
48-000-008	2/21/2022	Outfall	--	Sunny	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
48-000-011	2/21/2022	Upstream Structure	1006	Sunny	38	<0.1	No	--	--	--	--	--	--	--	--	--	--
50-000-004	1/26/2022	--	--	Sunny	23	<0.1	No	--	--	--	--	--	--	--	--	--	--
52-000-011	2/16/2022	--	--	Sunny	32	<0.1	No	--	--	--	--	--	--	--	--	--	--
55-000-001	4/4/2022	--	--	Sunny	41	<0.1	No	--	--	--	--	--	--	--	--	--	--
64-000-003	3/17/2022	Upstream Structure	2638	Cloudy	42	<0.1	No	--	--	--	--	--	--	--	--	--	--
65-000-004	1/25/2022	--	--	Sunny	40	<0.1	No	--	--	--	--	--	--	--	--	--	--
68-000-001	4/22/2022	Outfall	--	Sunny	63	<0.1	No	--	--	--	--	--	--	--	--	--	--
71-000-003	1/26/2022	--	--	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
71-000-004	1/26/2022	--	--	Sunny	27	<0.1	No	--	--	--	--	--	--	--	--	--	--
71-000-007	3/17/2022	Outfall	--	Cloudy	42	<0.1	No	--	--	--	--	--	--	--	--	--	--
75-000-004	3/17/2022	Outfall	--	Cloudy	45	<0.1	No	--	--	--	--	--	--	--	--	--	--
75-000-005	3/17/2022	Outfall	--	Cloudy	50	<0.1	No	--	--	--	--	--	--	--	--	--	--
77-000-003	1/24/2022	--	--	Sunny	28	<0.1	No	--	--	--	--	--	--	--	--	--	--
83-000-002	4/12/2022	Outfall	--	Cloudy	55	<0.1	No	--	--	--	--	--	--	--	--	--	--
84-000-001	4/22/2022	--	--	Sunny	62	<0.1	No	--	--	--	--	--	--	--	--	--	--
84-000-002	4/22/2022	--	--	Sunny	62	<0.1	No	--	--	--	--	--	--	--	--	--	--
WC-023	3/31/2022	--	--	Cloudy	11.9	<0.1	No	--	--	--	--	--	--	--	--	--	--





**Town of Scituate, MA**  
**MS4 General Permit Year 4**  
**Dry Weather Outfall Screening Results**

WC-031	4/14/2022	Upstream Structure	Unmapped catch basin on Arborway Dr.	Cloudy	46	<0.1	No	--	--	--	--	--	--	--	--	--	--
WC-037	4/14/2022	Outfall	--	Cloudy	46	<0.1	No	--	--	--	--	--	--	--	--	--	--
WC-046	3/17/2022	Outfall	--	Cloudy	50	<0.1	No	--	--	--	--	--	--	--	--	--	--

**Notes:**

1. Where outfalls were not screened, the next upstream drainage structure was used to determine the presence of dry weather flows.
2. The number in this field is associated with the GIS Object ID.
3. "--" = not sampled due to lack of flow, standing water, outfall/upstream drainage structure(s) not located/obstructed, or access denied
4. "ppm" = parts per million
5. "ppt" = parts per thousand
6. "<" = parameter not detected above field test instrument detection limit.