




Massachusetts Department of Environmental Protection
 Bureau of Water Protection – Wastewater Management Program
Sanitary Sewer Overflow (SSO)/Bypass
Notification Form

FOR DEP USE ONLY

Tax Identification Number _____

A. Reporting Facility

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



1. Facility Information

Town of Scituate, Sewer Division
 Reporting Sewer Authority

MA0102695
 Permit #

2. Authorized Representative Transmitting Form:

William
 First Name

Branton
 Last Name

781-545-8736
 Telephone No.

Supervisor
 Title

wbranton@scituatema.gov
 E-mail Address

B. Phone Notifications:

See DEP Regional Office telephone and fax numbers at the end of this form.

1. MassDEP staff contacted:

David
 first name

Burgs
 last name

Date/Time contacted:

2/1/22
 Date

8:18
 Time

am pm

2. EPA staff contacted:

David
 first name

Luriny
 last name

Date/Time EPA contacted:

2/1/22
 Date

8:30
 Time

am pm

3. Board of Health contacted:

Andrew
 First Name

Scheele
 Last Name

Date/Time contacted:

2/1/22
 Date

9:12
 Time

am pm

4. Others notified (select all that apply);

Conservation Commission

Harbormaster

Shellfish Warden

Division of Marine Fisheries

Downstream Drinking Water Supplier

Watershed Association

Beach Resource Manager

Other:

DPW Director Kevin Cafferty
 (specify)

C. SSO Information

1. SSO Discovered:

2/1/22
 Date

7:00
 Time

am pm

By:

Plant Staff

2. SSO Stopped:

2/1/22
 Date

7:05
 Time

am pm

3. SSO Discharge from:

Sanitary Sewer Manhole

Pump Station

Backup into Property

Other:

Septic Holdings Tank
 (specify)

4. SSO Discharge to: Ground Surface (no release to surface water)

Direct to Receiving Water

(surface water)

Catch basin to Receiving Water

(surface water)

Backup into Property Basement



Sanitary Sewer Overflow (SSO)/Bypass Notification Form

Tax Identification Number

C. SSO Information (cont.)

Location: 161 Dr. Fleming Septage holding tanks
(Description of discharge site or closest address)

5. Estimated SSO Volume at time of this Report: 2500 gallons septage + 16,200 gallons treated effluent

Method of Estimating Volume: Equipment Manufacturer's 30 gpm flow rate on equipment

6. Cause of SSO Event:

Rain Event Pump Station Failure Insufficient Capacity in System

Treatment Unit failure

Sewer System Blockage: Pipe Collapse Root Intrusion Grease Blockage

Other: Reversing unit malfunction, overloaded tanks with treated effluent flushing water.
(Specify)

7. Corrective Actions Taken:

Shut down unit. Pumped excess water back into process tanks (overloaded unit tank)
Called for loader to remove snow piles from catch basins to check basins
Checked outfall #2 for flow/discolored sewer. No flow or discolored sewer found.
Clearing yard of debris and disinfecting affected areas. Hosing down inside
of septage building basement and disinfecting floors.

Impact Area cleaned and/or disinfected: Yes No

Corrective Actions Completed: Yes No

Removed excess snow and cleaned catch basins. Removed contaminated ice/slush from
perimeter on yard. Hosed down and cleaned inside of septage building basement.

D. Comments/Attachments/Follow-up

I wish to provide (select all that apply):

Attachment Additional comments below: No additional comments or attachments

Additional comments and planned actions:

Catch basins covered in large snow pile due to recent blizzard. Septage tank
grassy area and snow prevented solids from entering basins. Outfalls appeared clean and
were not flowing (likely partially frozen)



Massachusetts Department of Environmental Protection
 Bureau of Water Protection – Wastewater Management Program
Sanitary Sewer Overflow (SSO)/Bypass
Notification Form

FOR DEP USE ONLY

Tax Identification Number

E. Certification Statement

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


 Signature of Authorized Representative

2/2/22
 Date Signed

Please keep a copy of this report for your records. When submitting additional information, include the MassDEP Incident Number from this report.

MassDEP Regional Office and EPA Telephone and Fax Numbers:

Northeast Region	Phone: 978-694-3215	Fax: 978-694-3499
Southeast Region	Phone: 508-946-2750	Fax: 508-947-6557
Central Region	Phone: 508-792-7650	Fax: 508-792-7621
Western Region	Phone: 413-784-1100	Fax: 413-784-1149
EPA	Phone: 617-918-1510	
EPA for Southeast Region, David Turin	Phone: 617-918-1598	Fax: 617-918-0598
EPA for Northeast, Central and Western Regions, Douglas Koopman	Phone: 617-918-1747	Fax: 617-918-0747
DEP 24-hour emergency	Phone: 888-304-1133	