



Massachusetts Department of Environmental Protection
 Bureau of Water Protection – Wastewater Management Program
Sanitary Sewer Overflow (SSO)/Bypass
Notification Form

FOR DEP USE ONLY

Tax Identification Number

A. Reporting Facility

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



1. Facility Information

Town of Scituate, Sewer Division
 Reporting Sewer Authority

MAG590041

Permit #

(MA 02695)

2. Authorized Representative Transmitting Form:

William
 First Name
 Supervisor

Branton
 Last Name

781-545-8736

Telephone No.

Title

wbranton@scituatema.gov
 E-mail Address

B. Phone Notifications:

See DEP Regional Office telephone and fax numbers at the end of this form.

1. MassDEP staff contacted:

Dave
 first name
 4/14/2023
 Date

Burns
 last name
 1:29
 Time

Date/Time contacted:

am pm

2. EPA staff contacted:

Dave
 first name
 4/14/2023
 Date

Turin
 last name
 1:40
 Time

Date/Time EPA contacted:

am pm

3. Board of Health contacted:

Andrew
 First Name
 4/14/2023
 Date

Scheel
 Last Name
 1:19
 Time

Date/Time contacted:

am pm

4. Others notified (select all that apply);

Conservation Commission

Harbormaster

Shellfish Warden

Division of Marine Fisheries

Downstream Drinking Water Supplier

Watershed Association

Beach Resource Manager

Other:

DPW Director
 (specify)

C. SSO Information

1. SSO Discovered:

4/14/2023
 Date

12:45
 Time

am pm

By:

Nate Ratcliff and Rosano Davis Operator Aiden Peterson

2. SSO Stopped:

4/14/2023
 Date

12:46
 Time

am pm

3. SSO Discharge from:

Sanitary Sewer Manhole

Pump Station

Backup into Property

Other:

Private Hauler
 (specify)

4. SSO Discharge to: Ground Surface (no release to surface water)

Direct to Receiving Water

(surface water)

Catch basin to Receiving Water

(surface water)

Backup into Property Basement



Massachusetts Department of Environmental Protection
 Bureau of Water Protection – Wastewater Management Program
Sanitary Sewer Overflow (SSO)/Bypass
Notification Form

FOR DEP USE ONLY

Tax Identification Number _____

C. SSO Information (cont.)

Location: 161 Driftway, WWTP Septage Receiving Station
 (Description of discharge site or closest address)

5. Estimated SSO Volume at time of this Report: 50

Method of Estimating Volume: Visual

6. Cause of SSO Event:

- Rain Event Pump Station Failure Insufficient Capacity in System
 Treatment Unit failure
 Sewer System Blockage: Pipe Collapse Root Intrusion Grease Blockage
 Other: Hose Malfunction
 (Specify)

7. Corrective Actions Taken:

Deployed spill protection and cover guards around and on catch basins, deployed vac
hosed down and disinfected affected areas, removed all material and liquids from ca
and all down stream catch basins and storm ceptors.

Checked outfall and took sample, water free normal, no odors, foam or solids

Impact Area cleaned and/or disinfected: Yes No

Corrective Actions Completed: Yes No

D. Comments/Attachments/Follow-up

I wish to provide (select all that apply):

- Attachment Additional comments below: No additional comments or attachments

Additional comments and planned actions:




Massachusetts Department of Environmental Protection
 Bureau of Water Protection – Wastewater Management Program
Sanitary Sewer Overflow (SSO)/Bypass
Notification Form

FOR DEP USE ONLY

Tax Identification Number

E. Certification Statement

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.


 Signature of Authorized Representative

4/14/2023

Date Signed

Please keep a copy of this report for your records. When submitting additional information, include the MassDEP Incident Number from this report.

MassDEP Regional Office and EPA Telephone and Fax Numbers:

Northeast Region	Phone: 978-694-3215	Fax: 978-694-3499
Southeast Region	Phone: 508-946-2750	Fax: 508-947-6557
Central Region	Phone: 508-792-7650	Fax: 508-792-7621
Western Region	Phone: 413-784-1100	Fax: 413-784-1149
EPA	Phone: 617-918-1510	
EPA for Southeast Region, David Turin	Phone: 617-918-1598	Fax: 617-918-0598
EPA for Northeast, Central and Western Regions, Douglas Koopman	Phone: 617-918-1747	Fax: 617-918-0747
DEP 24-hour emergency	Phone: 888-304-1133	