



Massachusetts Department of Environmental Protection
 Bureau of Water Protection – Wastewater Management Program
Sanitary Sewer Overflow (SSO)/Bypass
Notification Form

FOR DEP USE ONLY

Tax Identification Number _____

A. Reporting Facility

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



1. Facility Information

Town of Scituate, Waste Water Treatment Plant
 Reporting Sewer Authority

MAG590041
 Permit #

2. Authorized Representative Transmitting Form:

William _____ Branton _____ 781-545-8736
 First Name Last Name Telephone No.
 Supervisor
 Title _____ wbranton@scituatema.gov
 E-mail Address

B. Phone Notifications:

See DEP Regional Office telephone and fax numbers at the end of this form.

1. **MassDEP staff** contacted: David Burns
 first name last name
 Date/Time contacted: 5/31/2023 9:48
 Date Time am pm
2. **EPA staff** contacted: David Turin
 first name last name
 Date/Time EPA contacted: 5/31/2023 9:49
 Date Time am pm
3. **Board of Health** contacted: Andrew Scheele
 First Name Last Name
 Date/Time contacted: 5/31/2023 9:46
 Date Time am pm
4. Others notified (select all that apply); Conservation Commission
 Harbormaster Shellfish Warden Division of Marine Fisheries
 Downstream Drinking Water Supplier Watershed Association
 Beach Resource Manager Other: _____
 (specify)

C. SSO Information

1. SSO Discovered: 5/31/2023 6:59
 Date Time am pm
 By: Nate Ratcliffe - On Call Operator
2. SSO Stopped: 5/31/2023 7:06
 Date Time am pm
3. SSO Discharge from: Sanitary Sewer Manhole Pump Station
 Backup into Property Other: WWTP Sand Filters
 (specify)
4. SSO Discharge to: Ground Surface (no release to surface water)
 Direct to Receiving Water _____
 (surface water)
 Catch basin to Receiving Water _____
 (surface water)
 Backup into Property Basement



Massachusetts Department of Environmental Protection
 Bureau of Water Protection – Wastewater Management Program
Sanitary Sewer Overflow (SSO)/Bypass
Notification Form

FOR DEP USE ONLY

Tax Identification Number _____

C. SSO Information (cont.)

Location: 161 Driftway, Filter Building
 (Description of discharge site or closest address)

5. Estimated SSO Volume at time of this Report: 50 gallons

Method of Estimating Volume: visual estimate and SCADA flow comparison

6. Cause of SSO Event:

Rain Event Pump Station Failure Insufficient Capacity in System

Treatment Unit failure

Sewer System Blockage: Pipe Collapse Root Intrusion Grease Blockage

Other: _____
 (Specify)

7. Corrective Actions Taken:

Throttled flow through facility using main gate, restored treatment capacity of the clarifier that was in failure, backwashed sand filters, cleaned area affected.

Impact Area cleaned and/or disinfected: Yes No


Corrective Actions Completed: Yes No

D. Comments/Attachments/Follow-up

I wish to provide (select all that apply):

Attachment Additional comments below: No additional comments or attachments

Additional comments and planned actions:



Massachusetts Department of Environmental Protection
Bureau of Water Protection – Wastewater Management Program
Sanitary Sewer Overflow (SSO)/Bypass
Notification Form

FOR DEP USE ONLY

 Tax Identification Number

E. Certification Statement

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

William Branton here

 Signature of Authorized Representative

5/31/2023

 Date Signed

Please keep a copy of this report for your records. When submitting additional information, include the MassDEP Incident Number from this report.

MassDEP Regional Office and EPA Telephone and Fax Numbers:

Northeast Region	Phone: 978-694-3215	Fax: 978-694-3499
Southeast Region	Phone: 508-946-2750	Fax: 508-947-6557
Central Region	Phone: 508-792-7650	Fax: 508-792-7621
Western Region	Phone: 413-784-1100	Fax: 413-784-1149
EPA	Phone: 617-918-1510	
EPA for Southeast Region, David Turin	Phone: 617-918-1598	Fax: 617-918-0598
EPA for Northeast, Central and Western Regions, Douglas Koopman	Phone: 617-918-1747	Fax: 617-918-0747
DEP 24-hour emergency	Phone: 888-304-1133	